



NATIONAL
ENVIRONMENTAL
TESTING, INC.

JUL 6 1998

Indianapolis Division
6964 Hillsdale Ct.
Indianapolis, IN 46250
Tel: (317) 842-4261
Fax: (317) 842-4286

ANALYTICAL REPORT

Mr. Richard Tyler
MILBANK MANUFACTURING INC
1400 E. HAVENS ST.
KOKOMO, IN 56901-3188

07/01/1998

NET Job Number: 98.04322
Page 1 of 3

Enclosed are the Analytical Results for the following samples submitted to NET, Inc. Indianapolis Division for analysis:

Project Description: TWICE WEEKLY WASTEWATER

Sample Number	Sample Description	Date Taken	Date Received
211278	OUTFALL 001	06/26/1998	06/26/1998

National Environmental Testing, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed.

Reproduction of this analytical report is permitted only in its entirety.

Project Representative

MIL0003173



NATIONAL
ENVIRONMENTAL
TESTING, INC.

JUL 6 1998

Indianapolis Division
6964 Hillsdale Ct.
Indianapolis, IN 46250
Tel: (317) 842-4261
Fax: (317) 842-4286

ANALYTICAL REPORT

Mr. Richard Tyler
MILBANK MANUFACTURING INC
1400 E. HAVENS ST.
KOKOMO, IN 56901-3188

07/01/1998

Job No.: 98.04322

Page 2 of 3

Date Received: 06/26/1998

Job Description: TWICE WEEKLY WASTEWATER

Sample Number / Sample I.D.	Sample Date/	Analyst &		Reporting		
Parameters	Result	Flag	Units	Date Analyzed	Method	Limit
211278	OUTFALL 001		06/26/1998			
Iron, ICP	0.15		mg/L	tjg / 06/30/1998	EPA 200.7	<0.10
Lead, ICP	<0.080		mg/L	tjg / 06/30/1998	EPA 200.7	<0.080
Silver, ICP	<0.020		mg/L	tjg / 06/30/1998	EPA 200.7	<0.020
Zinc, ICP	1.5		mg/L	tjg / 06/30/1998	EPA 200.7	<0.020

MIL0003174



NATIONAL
ENVIRONMENTAL
TESTING, INC.

JUL 6 1998

Indianapolis Division
6964 Hillsdale Ct.
Indianapolis, IN 46250
Tel: (317) 842-4261
Fax: (317) 842-4286

FIELD REPORT

JOB #: 98.04322
CLIENT: MILBANK MFG.
PROJECT: TWICE WEEKLY WASTEWATER
DATE: 6/26/98
SAMPLER(S): NTH

An ISCO model 2910 auto sampler was used in the composite mode of operation. The sampler was equipped with a plastic composite jug, tygon suction line, battery, ice, and strainer.

All reusable equipment is decontaminated withalconox, tap water, 5% nitric acid, and deionized water. New tygon suction tubing was used for the sampler. A stainless steel strainer was also used for the sampling event.

The sampler was set to take a sample every 30 minutes for 24 hours.

Monitoring start 8:00 on 6/25/98
Monitoring end 8:00 on 6/26/98

The composite sample was cloudy, milky-white color.

Notes: Samples were preserved, in the field, in the appropriate containers with any required preservative.

MIL0003175



COMPANY Midbank
ADDRESS _____
PHONE _____ FAX _____
PROJECT NAME/LOCATION _____
PROJECT NUMBER Twice Weekly
PROJECT MANAGER _____

NET QUOTE NO. 98.0060

COMMENTS

[illegible]

TEMPERATURE UPON RECEIPT: 5.4°C
Bottles supplied by NET? (YES) NO

SAMPLE REMAINDER DISPOSAL: RETURN SAMPLE REMAINDER TO CLIENT VIA _____
I REQUEST NET TO DISPOSE OF ALL SAMPLE REMAINDERS

RELINQUISHED BY:	DATE 6/26/98	TIME 1:00	RECEIVED BY: N. Todd Hinkle	RELINQUISHED BY: N. Todd Hinkle	DATE 6/26/98	TIME 3:15	RECEIVED FOR NET BY: Wall
METHOD OF SHIPMENT			REMARKS:				

METHOD OF SHIPMENT

REMARKS: